

STORLYTICS BATTERY SCORE SHEET

EnerVenue Energy Storage Vessel (ESV)

Use Case

Augmentation
Med. Cycle Count
Deep Discharge

1. THE STORLYTICS REVIEW

Overall, Storlytics found that the ESV is advantageous from a cost of ownership standpoint for the studied use-case. This is due to its superior cycle life compared to that of Li-Ion. Further, the rate of degradation of the ESV was found to be less than that of lithium. Both factors resulted in a smaller required BoL capacity for EnerVenue's system compared to that needed for Li-Ion. This led to considerable capital cost savings. The ESV does underperform against lithium in self-discharge, RTE and energy density. However, cost of lifetime energy losses was found to be much less than the capital cost premium that was required for the Li-Ion benchmark.

While Storlytics believes that the results of this report can be applicable to most battery projects with similar use-cases, we recommend that developers model their planned battery systems and use-cases in Storlytics' Software to determine expected efficiency, life cycle, degradation and resulting financial benefits (or lack thereof) of their specific case. This, allows for project specific aspects like location ambient temperature profiles, system configuration, use-case and deployment strategy to be considered.

IMPORTANT: Scores shown here are only indicative of the use-case shown in section 3. Simulation files have been made public in the link shown in the appendix. Developers should leverage these files and edit them to simulate their specific use-cases as results will vary.

Technical Scores

Scores are based on EnerVenue battery performance of specified use-case in section 3




Figure 1. Radar chart for technical comparison

Table I. Technical Scoring

	EnerVenue ESV	Lithium LFP
<i>BoL Instl. Capacity</i>	4.7	3.3
<i>Usable DoD</i>	4.0	2.7
<i>Cycle RTE</i>	3.8	4.5
<i>Avg. Deg. Rate</i>	4.7	2.0
<i>Self-Dsch Rate (%/Day)</i>	3.7	4.9

Cost of Ownership Scores

The financial comparison below is based on project cost to meet performance requirements in section 3




Figure 2: EnerVenue cost of ownership benchmark

STORLYTICS BATTERY SCORE SHEET

EnerVenue Energy Storage Vessel (ESV)

2. Battery General Specifications

EnerVenue's main battery product is the ESV (Energy Storage Vessel) large format module. A string is a collection of ESVs connected in series to produce the proper voltages necessary to connect to inverters, DC/DC converters and other power conversion systems. 1500 Vdc strings utilize up to 153 ESVs with a system voltage range of approximately 1010 - 1500 Vdc at 25°C. Fewer ESVs will be required in the string in colder climates. Table II shows the specification of the ESV, and Figure 3 illustrates the battery technology. Figures 4.a and 4.b illustrate charge and discharge cycles cell voltage variation at different temperatures.

Table II. EnerVenue (ESV) module specifications

Battery OEM	EnerVenue
Product Name	Energy Storage Vessel (ESV)
Product Dscrp.	Common Pressure Vessel (CPV) with 6 internal cells connected in series
Chemistry	Nickel Hydrogen
Rated Energy	1.2 kWh
Temp Range	-15 to 55°C
DoD Range*	97%
Perf. Guarantee Cycles**	20,000
Temperature Mgmt.	Convection forced air without active refrigeration cycle

*Based on operation at 0.25C at 20 °C

** Number of cycles covered by OEM performance guarantee




Figure 3. Representation of EnerVenue (ESV) battery system




Figure 4.a. Charge cycle cell voltage vs. dsch. Energy




Figure 4.b. Discharge cycle cell voltage vs. dsch. Energy

STORLYTICS BATTERY SCORE SHEET

EnerVenue Energy Storage Vessel (ESV)

3. Scored Use Case

Technical and cost of ownership values were deduced based on performing the use-case described in this section. The use-case profile shown in Figure 5 is assumed to be executed daily for the entirety of the project life. The Beginning of Life (BoL) energy capacity for the Enervenue batteries was sized to allow the system to maintain the Energy Capacity Requirement as outlined in Table III. Lithium benchmark BoL is sized with an initial overbuild and three augmentation phases at years 5,12, and 15 to meet the Table III requirements.

Storlytics simulated both EnerVenue’s (ESV) battery and a tier-1 Li-Ion (LiFePO₄) battery executing the POI profile shown in Figure 5. This simulation leveraged fully validated battery models developed within Storlytics software. Storlytics software’s native file format for batteries is (.btt). EnerVenue’s battery model was developed and validated for operation at a temperature of 20°C. The Li-Ion (LiFePO₄) model was developed and validated for 24°C cell temperature. The Li-Ion system degradation model was validated using SoH guarantee data from dozens of projects offered by a tier-1 Li-Ion battery OEM. Modeling accounted for variance in cycle DoD, C-rate, avg SoC, and project life. Table IV provides specifications required of both systems to meet performance requirements described in Table III.

Table III. Performance requirements

Power Req. at POI	25 MW
Duration Req.	4 hours
EoL Dsch Energy Req. at POI	100 MWh
Project Life	20 Years
Cycle Count per Day	1.75 Cycles
Cycle Count per Asset Life	12,775 Cycles
Deployment Strategy	EnV: Overbuild; Li-
Applications	Ion:Augmentation Energy Arbitrage PV clipped Energy

Table IV. System specifications required to perform use-case

	EnerVenue (ESV)	Lithium (LFP)
<i>Simulation Amb. Temp</i>	20 °C	24 °C
<i>Required BoL Energy</i>	112.36 MWh	127.48 MWh
<i>Required Augmentation</i>	None	Y5 – 30 MWh Y12 – 115 MWh Y15 – 30 MWh
<i>Max SoC</i>	100%	96%
<i>Min SoC</i>	3%	3%




Figure 5. Point of Interconnection (POI) profile for both Li-Ion (LiFePO₄) and EnerVenue (ESV) systems

STORLYTICS BATTERY SCORE SHEET

EnerVenue Energy Storage Vessel (ESV)

4. Cell Degradation

The degradation of both battery systems was characterized by the following points:-

- It is noted that the EnerVenue system has significantly superior capacity degradation characteristics than the designed Li-Ion (LiFePO₄) system.
- For a 20-year project life, the EnerVenue (ESV) system shows a Beginning of Life energy requirement of 112.86 MWh, and no augmentation is required.
- Figure 6 and Table V indicate that the BoL capacity required for the Li-Ion (LiFePO₄) system Phase 1 is 127.48 MWh.
- At year 5, the Phase 1 DC energy capacity of 103.73 MWh falls below the 107 MWh DC energy threshold and triggers an augmentation cycle.
- At year 12, the Phase 1 SoH falls below OEM recommended 65% SoH, the battery cells from Phase 1 are replenished, and 115 MWh of new battery cells are installed as part of Phase 3.
- At year 15, as part of phase 4, 30 MWh of energy capacity is added. A significant amount of energy augmentation is needed for the Li-Ion (LiFePO₄) systems. Table V shows the degradation comparison of both systems.
- DC augmentation provides some implementation challenges, which are not covered under this study.

Table V. Degradation comparison of both systems.

Year	EnerVenue (ESV)		Li-Ion (LiFePO ₄)			
	DC Capacity (MWh)	DC Capacity (MWh)				
		Phase 1	Phase 1	Phase 1	Phase 1	Total
0	112.36	127.48				127.48
1	111.97	118.28				118.28
2	111.57	114.44				114.44
3	111.18	110.75				110.75
4	110.79	107.19				107.19
5	110.40	103.73	30.00			133.73
6	110.01	100.39	27.84			128.23
7	109.62	97.16	26.93			124.09
8	109.24	94.03	26.06			120.09
9	108.85	91.00	25.23			116.23
10	108.47	88.07	24.41			112.48
11	108.09	85.23	23.63			108.86
12	107.71	0.00	22.87	115.00		137.87
13	107.33	0.00	22.13	106.70		128.83
14	106.96	0.00	21.42	103.24		124.66
15	106.58	0.00	20.73	99.92	30.00	150.64
16	106.20	0.00	20.06	96.70	27.84	144.59
17	105.83	0.00	0.00	93.58	26.93	120.51
18	105.46	0.00	0.00	90.57	26.06	116.63
19	105.09	0.00	0.00	87.65	25.23	112.88
20	104.72	0.00	0.00	84.83	24.41	109.24




Figure 6. Energy capacity degradation comparison between EnerVenue (ESV) and Li-Ion (LiFePO₄)

STORLYTICS BATTERY SCORE SHEET


EnerVenue Energy Storage Vessel (ESV)

5. Cost of Ownership Results

The following major factors contributed to the EnerVenue system achieving a more advantageous lifetime cost of ownership cost.

- ⊗ The EnerVenue (ESV) battery system has significantly superior capacity degradation performance compared to the Li-Ion (LiFePO₄) system.
- ⊗ The EnerVenue system required an initial Beginning of Life(BoL) capacity of 112 MWh compared to Li-Ion's 127.48 MWh BoL and three augmentation phases of 30,115 and 30 MWh.
- ⊗ Accordingly, the DC Block capital cost of the EnerVenue system (\$39 MM) was deduced to be less than that of the Li-Ion system with augmentation (\$ 67 MM).
- ⊗ The EnerVenue system did, however, achieve a lower DC round-trip efficiency (RTE) of 90.02% compared to the Li-Ion (LiFePO₄) system's 96.11%, for the same use case described in section 3.
- ⊗ Accordingly, the annual energy loss cost was more for the EnerVenue system (\$ 790,513) than for the Li-Ion system (\$301,647).

As a result of these factors, and as shown in Table VI, and Figure 7, the total cost of ownership for executing this high cycle use-case was found to be more advantageous with the EnerVenue battery.



- DC Block Capital Cost(\$)- Year 0
- DC Block Capital Cost(\$)- Augmentation
- Mobilization/Demobilization Cost(\$)
- AC System Capital Cost(\$)
- NPV Cost of SOH Guarantee(\$)
- NPV Cost of Energy Loss (\$)

Figure 7. Ownership cost distribution of both system.

Table VI. Financial comparison between EnerVenue (ESV) and the Li-Ion (LiFePO₄) systems

	EnerVenue (ESV)	Li-Ion (LiFePO ₄)
Project Life	20 years	20 years
Cost per unit energy (\$/kWh)	350	285
Required BoL Energy Capacity (MWh)	112.36	127.47
DC Block Capital Cost(\$)- Year 0	\$ 39,326,000	\$36,328,950
DC Block Capital Cost(\$)- Augmentation	\$0	\$30,935,381
DC Block Capital Cost(\$)- Total	\$39,326,000	\$67,264,331
AC System Capital Cost(\$)	\$ 2,400,000	\$2,160,000
Mobilization/Demobilization		\$215,756
Total System Capital Cost(\$)	\$ 41,726,000	\$ 69,640,086
SoH Guarantee Cost per year (\$)	\$ 179,776	\$184,832
NPV Cost of SOH Guarantee(\$)	\$ 2,715,387	\$2,791,747
Energy Loss Per Year (MWh)	7186.49	2,742.25
Cost of Energy Loss per Year(\$)	\$ 790,513	\$ 301,647
NPV Cost of Energy Loss (\$)	\$ 11,760,842	\$ 4,487,745
NPV of Total Running Cost(\$)	\$ 14,476,229	\$ 7,279,492
Discount rate	3%	3%
Total Cost (\$)	\$ 56,202,229	\$ 76,919,578
Required EoL Energy(MWh)	100	100
Effective Cost per Required EoL Energy(\$/kWh)	\$ 562	\$ 769

APPENDIX

Scoring Background

Storlytics Battery Score Sheets (BSSs) evaluate new ES technologies based on defined use cases. This is because performance characteristics of battery systems, like losses, auxiliary load, and degradation, vary widely based on the use case they execute over their lifetime. Additionally, most battery technologies are heavily affected by the meteorological conditions of install location. Therefore, it becomes imperative to associate battery technology ratings with use cases and any other tech-specific modeling details. This scoring compares the performance of the EnerVenue (ESV) energy storage system with a tier-1 Li-Ion(LiFePO₄) storage system. The score sheet provides insights about the following features:-

- ⊗ EnerVenue battery degradation compared to a tier-1 Li-Ion(LiFePO₄) system for a multi-cycle per day use case
- ⊗ EnerVenue energy storage system's efficiency compared to a Li-Ion(LiFePO₄) system
- ⊗ Overall cost of ownership of the EnerVenue system compared to the Li-Ion(LiFePO₄) benchmark

Acronyms

BESS	Battery Energy Storage Systems	NPV	Net Present Value
BoL	Beginning of Life	SoC	State of Charge
CPV	Common Pressure Vessel	SoH	State of Health
DOD	Depth of Discharge	OCV	Open Circuit Voltage
EoL	End of Life	LFP	Lithium Iron Phosphate
ESV	Energy Storage Vessel	RTE	Round Trip Efficiency
IPV	Individual Pressure Vessel	PPC	Power Plant Controller

Full Report Access

The full report for this analysis is titled *“Technology Evaluation of Enervenue Nickel-hydrogen (ESV) 160ah Battery Cell”*. It consists of two main parts: -

1. *“Part I: Characterization & Modeling”*
2. *“Part II: Performance Benchmarking Against Li-Ion LFP Systems”*

The full report of this analysis is made available by Storlytics Energy Storage. To receive a copy, please contact support@storlytics.net.

Simulation Files

The simulation files used to deduce the results in this score sheet can be found through this link:

[Download Simulation Files](#)

To simulate your own use-case, simply download the simulation files, and edit the system sizing and POI Profile per your case.

About Storlytics

Storlytics is a US based consulting and software firm specializing in grid-tied energy storage systems. Our team of PhDs and professional engineers support and partner with industry leading integrators, battery OEMs ,utilities, Universities, and national labs to develop accurate models for conventional and new grid tied battery energy storage systems. This allows us to perfect our energy storage modeling software Storlytics® for our clients.

Our mission is simple, **“Enable renewable energy developers, integrators, and utilities to easily design and optimize energy storage projects”**

Storlytics’ engineers bring more than 20 years of combined energy storage industry experience into the simulation of grid tied battery systems within the Storlytics platform.

Recognizing major industry pain points in uncertainty of degradation and system loss profiles of battery energy storage systems, the Storlytics team built the Storlytics platform to accurately estimate expected degradation of battery energy storage systems, allowing our users to reduce project uncertainty and risk. This also allows our users to optimize project design and select the best battery technology and OEM for the user’s specific case.

For more information about Storlytics software and consulting services, please reach out to support@storlytics.net.